

Sweet Potato Storage VFD Analysis

1 3hp fans=3hp, 16800 CFM per fan at .5" static pressure

Project Name **XYZ Potato Shed**
 Contact **Sweet Potato grower**
 Contact Phone No.
 Location **MS,AR,NC,LA,CA**
 Farm Name **Sweet Potatoes**
 Storage Capacity (ton) **250**
 Storage Capacity (BU) **10,000**
 Design Airflow (cfm/BU) **1.5**
 Total Fan HP **3**
 Fan Motor Loading (est) **95%**
 Fan Motor Efficiency **95%**
 Calculated Fan Use (kW) **2.2**
 VFD Efficiency **95%**
 Total Measured Fan (kW) **2.2**
 Refrigerated (Yes/No) **No**

Blue = User Inputs

Utility Provider **Power Utility**
 Utility Contact **Power Rep**
 Energy Cost (\$/kWh) **\$0.100**
 Avg Energy Consumption **10,129 kWh**
 Estimated Energy Savings **6,602 kWh**
 Percent Energy Savings **65% (range 30-60%)**
 Energy Cost Savings **\$660.22**
 Estimated Project Cost **\$675.00**
 Potential Incentive **\$472.50**
 Payback w/o incentive (yr) **1.0**
 Payback with incentive (yr) **0.3** please contact PU

Fan output in cfm	16800	CFM per fan
at different air press	1	Number of fans
	16800	Total CFM at .5 static press
	20000	Total CFM at .05 static press
	1.68	CFM per BU at .5 static press
	2	CFM per BU at .05 static press

\$225.00 cost of the VFD per hp
 (may need to adjust formula)

No VFD (Current) Ventilation System Profile						
Storage Phase	Starting Dates	Days	Fans In-Use	Fan Run Time	Calculated Usage	Typical Fan Operation
			(%)	(hr/day)	(kWh)	
Harvest / Load	9/15/2006	5	100%	10	112	Start fans when loading
Cure / Suberize	9/20/2006	14	100%	24	752	Continuous/Recirc if no OSA
Ramp to Hold Temp	10/4/2006	30	100%	24	1,611	Run Anytime OSA Avail
Winter Holding	11/3/2006	90	100%	24	4,834	Run Anytime OSA Avail
Spring Holding	2/1/2007	60	100%	18	2,417	Run Anytime OSA Avail
Unload	4/2/2007	15	100%	12	403	Continuous w/ OSA or Refrig
empty	4/17/2007	0	100%	0	0	Run Anytime OSA Avail
Storage Season Length		214		Total =	10,129	usage w/o VFD's in kWh
					\$1,012.92	En. cost w/o VFD's in \$\$

Estimated VFD Ventilation System Operation Profile						
Storage Phase	Starting Dates	Days	Fan Speed	Fan Run Time	Calculated Usage	Typical Fan Operation
			(%)	(hr/day)	(kWh)	
Harvest / Load	9/15/2006	5	70%	10	47	Start fans when loading
Cure / Suberize	9/20/2006	14	100%	24	792	Continuous/Recirc if no OSA
Ramp to Holding Temp	10/4/2006	30	80%	24	950	Run Anytime OSA Avail
Winter Holding	11/3/2006	90	50%	24	839	Run Anytime OSA Avail
Spring Holding	2/1/2007	60	65%	18	830	Run Anytime OSA Avail
Unload	4/2/2007	15	50%	12	70	Continuous w/ OSA or Refrig
empty	4/17/2007	0	0%	0	0	Run Anytime OSA Avail
Storage Season Length		214		Total =	3,527	usage with VFD's in kWh/Yr

Estimated Yearly energy cost =	\$352.70	En. cost with VFD's in \$\$
Estimated Savings =	6,602	kWh per year savings
	\$660.22	Net power savings/yr in \$\$
10 year lifespan of the project as per DOE	\$6,602.19	10 year savings \$\$
Avg cost of 10000 bu computerized system	\$9,300	total ventilation system cost
	\$2,698	vent system net cost after
	70.99%	deduction of 10 yr/main fan VFD savings

Notes:

Use utility billing history to help verify storage time
 Work with grower to determine tonnage/BU by month (eg unloading reduces refrigeration need)
 Please check with power utility on rebate and power filtration system requirements
 For these estimates, use 50% as the lowest VFD speed
 Savings should be based on kWh per day, however, tonnage/BU may also need to be factored in.
 Energy savings may not be reflected on power bill until later in storage season.
 For verification of savings, update spreadsheet using actual monthly VFD run time and kWh data and billing history

BOOSTER FANS ARE NEEDED TO CARRY THE AIR OVER 60' FOR STORAGES OF 80'+ IN LENGTH - FANS SHOULD CARRY 75% OF THE TOTAL MAXIMUM AIR AVAILABLE

