

Sweet Potato Sto VFD Analysis NC style

4 3hp fans=12hp , 16,800 CFM per fan at .5" static pressure

Project Name **XYZ Potato Shed**
 Contact **Sweet Potato grower**
 Contact Phone No.
 Location **MS,AR,NC,LA,CA**
 Farm Name **Sweet Potatoes**
 Storage Capacity (ton) **1,250**
 Storage Capacity (BU) **50,000**
 Design Airflow (cfm/BU) **1.5**
 Total Fan HP **12**
 Fan Motor Loading (est) **95%**
 Fan Motor Efficiency **95%**
 Calculated Fan Use (kW) **9.0**
 VFD Efficiency **95%**
 Total Measured Fan (kW) **9.0**
 Refrigerated (Yes/No) **No**

Blue = User Inputs

Fan output in cfm	16800	CFM per fan
at different air press	4	Number of fans
	67200	Total CFM at .5 static press
	80000	Total CFM at .05 static press
Utility Provider	Power Utility	1.344
Utility Contact	Power Rep	1.6
Energy Cost (\$/kWh)	\$0.100	
Avg Energy Consumption	40,517	kWh
Estimated Energy Savings	26,409	kWh
Percent Energy Savings	65%	(range 30-60%)
Energy Cost Savings	\$2,640.88	\$\$
Estimated Project Cost	\$2,700.00	\$225.00
Potential Incentive	\$1,890.00	cost of the VFD per hp
Payback w/o incentive (yr)	1.0	(may need to adjust formula)
Payback with incentive (yr)	0.3	please contact PU

No VFD (Current) Ventilation System Profile						
Storage Phase	Starting Dates	Days	Fans In-Use	Fan Run Time	Calculated Usage	Typical Fan Operation
			(%)	(hr/day)	(kWh)	
Harvest / Load	9/15/2006	5	100%	10	448	Start fans when loading
Cure / Suberize	9/20/2006	14	100%	24	3,008	Continuous/Recirc if no OSA
Ramp to Hold Temp	10/4/2006	30	100%	24	6,445	Run Anytime OSA Avail
Winter Holding	11/3/2006	90	100%	24	19,336	Run Anytime OSA Avail
Spring Holding	2/1/2007	60	100%	18	9,668	Run Anytime OSA Avail
Unload	4/2/2007	15	100%	12	1,611	Continuous w/ OSA or Refrig
empty	4/17/2007	0	100%	0	0	Run Anytime OSA Avail
Storage Season Length		214		Total =	40,517	usage w/o VFD's in kWh
					\$4,051.68	En. cost w/o VFD's in \$\$

Estimated VFD Ventilation System Operation Profile						
Storage Phase	Starting Dates	Days	Fan Speed	Fan Run Time	Calculated Usage	Typical Fan Operation
			(%)	(hr/day)	(kWh)	
Harvest / Load	9/15/2006	5	70%	10	186	Start fans when loading
Cure / Suberize	9/20/2006	14	100%	24	3,166	Continuous/Recirc if no OSA
Ramp to Holding Temp	10/4/2006	30	80%	24	3,798	Run Anytime OSA Avail
Winter Holding	11/3/2006	90	50%	24	3,357	Run Anytime OSA Avail
Spring Holding	2/1/2007	60	65%	18	3,320	Run Anytime OSA Avail
Unload	4/2/2007	15	50%	12	280	Continuous w/ OSA or Refrig
empty	4/17/2007	0	0%	0	0	Run Anytime OSA Avail
Storage Season Length		214		Total =	14,108	usage with VFD's in kWh/Yr

Estimated Yearly energy cost =	\$1,410.80	En. cost with VFD's in \$\$
Estimated Savings =	26,409	kWh per year savings
	\$2,640.88	Net power savings/yr in \$\$
10 year lifespan of the project as per DOE	\$26,408.75	10 year savings \$\$
Avg cost of 50,000 bu computerized system	\$38,000	total ventilation system cost
	\$11,591	vent system net cost after
	69.50%	deduction of 10 yr/main fan VFD savings

Notes:

Use utility billing history to help verify storage time
 Work with grower to determine tonnage/BU by month (eg unloading reduces refrigeration need)
 Please check with power utility on rebate and power filtration system requirements
 For these estimates, use 50% as the lowest VFD speed
 Savings should be based on kWh per day, however, tonnage/BU may also need to be factored in.
 Energy savings may not be reflected on power bill until later in storage season.
 For verification of savings, update spreadsheet using actual monthly VFD run time and kWh data and billing history

BOOSTER FANS ARE NEEDED TO CARRY THE AIR OVER 50', FOR STORAGES OF 60'+ IN LENGTH FANS SHOULD CARRY min 75% OF THE TOTAL AIR AVAILABLE

